US Army Corps
of Engineers
Waterways Experiment
Station

CONSTRUCTION PRODUCTIVITY ADVANCEMENT RESEARCH (CPAR) PROGRAM

Interference Checking of Construction Design

by

Arthur Bennett, Ken Cook, Gregory A. Covington,
Laurel T. Gorman, Albert N. Williamson

DTIC
SELECTED
APR 1 1 1995
G

19950407 156

**A Corps/Industry Partnership to Advance
Construction Productivity and Reduce Costs**

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official endorsement or approval of the use of such commercial products.

Interference Checking of Construction Design

by   Arthur Bennett

U.S. Army Engineer District, Walla Walla
Bldg. 602, City County Airport
Walla Walla, WA   99362-9265

Ken Cook, Gregory A. Covington, Laurel T. Gorman, Albert N. Williamson

U.S. Army Corps of Engineers
Waterways Experiment Station
3909 Halls Ferry Road
Vicksburg, MS   39180-6199

Accesion For		
NTIS CRA&I	☒	
DTIC TAB	☐	
Unannounced	☐	
Justification		
By		
Distribution /		
Availability Codes		
Dist	Avail and / or Special	
A-1		

Final report

US Army Corps
of Engineers
Waterways Experiment
Station

N

INFORMATION
TECHNOLOGY
LABORATORY

HEADQUARTERS
BUILDING

GEOTECHNICAL
LABORATORY

MAIN
ENTRANCE

HYDRAULICS
LABORATORY

COASTAL ENGINEERING
RESEARCH CENTER

ENVIRONMENTAL
LABORATORY

FOR INFORMATION CONTACT :
PUBLIC AFFAIRS OFFICE
U. S. ARMY ENGINEER
WATERWAYS EXPERIMENT STATION
3909 HALLS FERRY ROAD
VICKSBURG, MISSISSIPPI 39180-6199
PHONE : (601)634-2502

STRUCTURES
LABORATORY

SCALE
800   0   800 m

AREA OF RESERVATION = 2.7 sq km

Contents

SF 298

Preface

The Construction Productivity Advancement Research (CPAR) program was authorized by Section 7 of the Water Resources Development Act of 1988. This Act authorized the Secretary of the Army to utilize the U.S. Army Corps of Engineers (Corps) laboratories and research centers to undertake collaborative research and development with the U.S. construction industry. This legislation, along with the Stevenson-Wydler Technology Innovation Act of 1980, as amended, is the basis for the cost-shared research, development, and demonstration CPAR program.

The project discussed herein, CPAR Project No. 901-930, stems from the Intergraph Corporation proposal No. 6-8903-21023, dated 23 May 1990, entitled "Cooperative Research and Development Agreement for Interdisciplinary Interference Checking Software." The CPAR project was conducted jointly by the Tri-Service CADD/GIS Technology Center, Information Technology Laboratory (ITL), U.S. Army Engineer Waterways Experiment Station (WES), and the CPAR Partner, Intergraph Corporation, Huntsville, Alabama. The Tri-Service CADD/GIS Technology Center was chartered in 1992 to foster the use of computer-aided design and drafting (CADD) and geographical information system (GIS) technologies for life-cycle facilities management within the Army, Navy, and Air Force. The Center operates under the direction of Dr. N. Radhakrishnan, Director, ITL, and Mr. Carl S. Stephens, Chief, Tri-Service CADD/GIS Technology Center. The Center functions under the direction of the Executive Steering Group, composed of Messrs. Richard Armstrong and Paul Barber, U.S. Army; Dr. Get Moy, Office of the Secretary of Defense (OSD); Dr. Robert Wolff, U.S. Air Force; and Mr. Harry Zimmerman, U.S. Navy. Dr. Wolff serves as chairman of the group. The Executive Steering Group's goals and objectives for the Center are guided through the efforts of the Executive Working Group chaired by Mr. Hugh Adams, U.S. Army. The group is composed of Messrs. Deke Smith and Jim Carberry, U.S. Navy; Maj David Biecheuval, Lt Col Kaminskas, and Mr. Don Ritenour, U.S. Air Force; Messrs. Adams, M. K. Miles, and Dr. Radhakrishnan, U.S. Army; and Mr. Tom Rutherford, OSD.

The U.S. Army Engineer District, Walla Walla, detailed Mr. Arthur Bennett to the Center for the purpose of testing and evaluating the interference checker and assisting in the preparation of this report. The

1 Introduction

Background

Spatial conflicts between building materials and equipment (i.e., multiple objects trying to occupy the same space) are often not discovered until a project is well into construction. Correcting these conflicts requires in-the-field modifications that can be expensive and time-consuming. Historically, designers and engineers have relied entirely on manual methods to identify possible spatial conflicts during the design of a project. Unfortunately, due to inadequate coordination among disciplines, conflicts continue to occur. For instance, working independently, a mechanical and electrical engineer may unknowingly locate heating, ventilation, and air conditioning (HVAC) ductwork and electrical conduit lines in the same location. Such common, and costly occurrences, illustrate the need for an interference-checking application that identifies conflicts early in the design when corrections can be made quickly and economically. Acknowledging these benefits, the Tri-Service CADD/GIS Technology Center, through its network of DoD designers and engineers, defined the requirements for a software application package capable of recognizing and reporting spatial conflicts based on three-dimensional (3-D) computer-aided design and drafting (CADD) models/construction drawings. The identification of this need and the recognition of its value to the construction industry led to the development of Intergraph's Model Interference Checker (MIC) and Interactive Interference Checker (IntIfc) under the Construction Productivity Research (CPAR) Program.

Purpose

This CPAR project was initiated to develop an automated method for diagnosing spatial conflicts during the design of a building by interrogating 3-D CADD drawings. Since designers typically use multiple hardware/software platforms to develop designs, the ideal automated package would accept spatial information, in various formats, from each design discipline involved in the design process (Figure 1). The locations of conflict would be displayed graphically and a descriptive list of all

Design Disciplines


Figure 1. Model Interference Checker (MIC) envelope files

interferences would be formulated to facilitate conflict remediation among the designers.

Scope

The scope of this CPAR project was to develop automated interference-checking software that accepts interdisciplinary design data in multiple formats and both identifies and documents potential spatial conflicts.

2 Software Development, Functional Description, and Operation

Software Development

The reliability of an interference-checking software application is dependent on the precise location of every item/component in a 3-D project model (drawing). Since various individuals with diverse expertise (including draftsmen, technicians, engineers, interior designers, and architects) contribute to the project model, a multiuser checking system is needed to detect spatial conflicts as each individual integrates their portion of the design into the project model. To this end, a computer software solution was pursued that methodically scrutinizes 3-D design models/construction drawings and identifies spatial conflicts. Appendix A defines the various design disciplines and their contributions to the completed project design model.

The underlying CADD software application used to generate the design models (drawings) discussed in this report was Intergraph Corporation's MicroStation version 4.0. MicroStation generates the 3-D CADD drawings necessary to support software applications, such as MIC and IntIfc, that require "intelligent graphics." Intelligent graphics are drawing elements such as lines, circles, and arcs that have nongraphic database information associated with them. With intelligent graphics, a simple shape such as a cylinder can be more accurately defined as a high pressure liquid gas tank or a shielded electrical conduit. Without 3-D models and intelligent graphics, advanced applications such as MIC cannot accurately identify interference or conflicts in CADD drawings.

Ideally, project models are portrayed in 3-D CADD drawings that, when combined, provide a holistic view of the project suitable for interference checking. Individual models are typically categorized by the design discipline responsible for its development (i.e., architectural, structural, mechanical, electrical). The design disciplines and associated 3-D drawing

models chosen to demonstrate and evaluate the capabilities of MIC and IntIfc were:

 a. Architectural - floor plans and sections.

 b. Mechanical - duct work and pipe layout.

 c. Structural - structural shapes and fittings.

Functional Description

The Model Interface Checker (MIC) was designed to provide designers with the tools necessary to analyze project models for interferences. Through MIC, a designer can interrogate a design model and obtain a detailed report of all interferences or spatial conflicts. MIC provides interference-checking and detection capabilities using input data from any Intergraph or MicroStation application that produces a 3-D model or combination of models. The models may originate from a variety of Intergraph application software packages, including Micas-Plus, ModelDraft, Project Architect, Project Engineer-HVAC, and Project Engineer-Pipe.

MIC detects three basic categories of interference: hard, soft, and construction. A hard interference is one that exists between actual physical objects. A soft interference exists between nonphysical space envelopes, i.e., pipe insulation and maintenance passageways. A construction interference exists when there is conflict between a user-defined distance and the actual distance separating two components in the design model; i.e. the user specifies a clearance requirement around a piece of equipment. If the model contains an object within the clearance space of that equipment, a construction interference will be reported. For example, if piping components are required to be at least 1 in. from all other structural components and an object is closer than 1 in., a conflict will be detected and reported.

Interferences are reported in ASCII or tabular form in order of precedence (according to hard, soft, and construction) in the following order: hard/hard, hard/soft, hard/construction, soft/soft, soft/construction, construction/construction.

Operating Environment

Model Interface Checker (MIC)

NOTE: To operate successfully, MIC requires that a project database be created (typically Informix or Oracle) prior to any application analysis. Once created, MIC manages all database connections internally. Informix and Oracle database creation and management are addressed in the MIC user manual but are not addressed herein.

MIC provides a front-end shell (user interface) that allows user access to the primary functional areas. These areas are:

a. *Project Administrator.* Project Administrator is used to create projects which in turn create the associated database schema necessary for MIC to access and manage database connections.

b. *Project Environment Manager.* Project Environment Manager provides the user with predefined forms and menus used to manage models (drawings) information within individual projects. As with Project Administrator, Project Environment is primary a "house keeping" function within the MIC application.

c. *Interference Management.* Interference Management provides the interference commands that build and verify envelope files and performs the actual interference checking. Running interference checking within Interference Management is a three-step process.

- *Step 1: Create envelope files.* To complete an interference check on a project model, MIC generates an **envelope file** for each drawing file in a project model. (All envelope files have a .env file name extension. For example, for a 3-D CADD drawing file named bceqp01.dgn, MIC creates an associated envelope file named bceqp01.env.) Each envelope file defines the volume and clearances of the objects or components in the associated drawing files. It is these envelope files that MIC evaluates to identify interferences and conflicts.

- *Step 2: Compare envelope files for spatial conflicts.* The user may identify particular drawing or portions of drawing to check for interferences. The user may also select the types of interference (hard/hard, hard/soft, hard/construction, etc). Once the particular files are chosen, and the type of interference is selected, the MIC application automatically evaluates the 3-D model drawing data and identifies the areas of conflict.

6

- *Step 3: Report conflicts.* MIC provides two types of spatial conflict reports. Graphical conflicts are shown as highlighted areas of the model drawings. Text reports are provided in ASCII or tabular form. See Appendixes B through D for examples.

Drawing elements detectable with MIC are confined to specific subtypes, including (numbers in parentheses indicate the Intergraph element type):

a. Surfaces (18)
subtype 0 = surface of projection
subtype 8 = surface of revolution

b. Solids (19)
subtype 0 = volume of projection

c. Cones (23)
subtype 0 = general (nonspecific) cone

d. Cells with nested primitives

Although MIC can operate with any of the Intergraph 3-D modeling applications, it is assumed that most users will use MIC in conjunction with the architectural and engineering applications that use relational databases such as Informix and Oracle. For the scope of this CPAR project, 3-D models (drawings) were developed within Project Architect, Project Engineer-HVAC, and Project Engineer-Pipe applications. Appendix E provides a general description of these applications.

Interactive Interference Checker (IntIfC)

The IntIfc software was provided as a supplement to the MIC product and was evaluated as a part of the CPAR project. IntIfc is a basic Microstation Development Language (MDL) application which provides the capability to detect interfering elements or vectors in 3-D MicroStation design files. Unlike MIC, IntIfc does not require a database or database schema. IntIfc automatically generates interference envelopes for components in the master design file and the attached reference model. However, it does not detect interferences between reference files. IntIfc is executable only through the Intergraph CLIX[1] environment via MicroStation 4.0 software or later versions.

Operation of the IntIfc product is initiated in a master design file through a key-in command line or through use of MDL applications available in a user pull-down menu.

---

[1] Intergraph's UNIX operating system.

After analysis of the model, a text file displays the total number of interferences detected during the interference checking process. Interferences are also displayed graphically in response to the system prompts—First, Next, Previous, or Last. In the displays, each interference appears on the monitor as highlighted line-work. A zoom-in/out capability is provided for detailed study of the selected view on the computer monitor.

As with MIC, the only MicroStation elements detectable under IntIfc are specific subtypes of solids (19), surfaces (18), cones (23), or cells with nested primitives. Interference checking is allowed between master design files and an attached reference files. The software does not permit interference checking between attached reference files. A report file (Figure 2) is generated but is not saved unless this option had been specifically selected.

8

```
Number of Clashes found = 27
Clash number 1
        Item A: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn
        Item B: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn

Clash number 2
        Item A: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn
        Item B: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn

Clash number 3
        Item A: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn
        Item B: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/rway01.dgn

Clash number 4
        Item A: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn
        Item B: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/rway01.dgn

Clash number 5
        Item A: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/igds01.dgn
        Item B: Generic
                Discipline : Unknown
                Model : /usr/newpipe/design/rway01.dgn
```

Figure 2. Typical interactive interference checker report

3 Evaluation Procedures

MIC

The evaluation procedure was structured to assess ease of application setup, execution, and use, and to determine if the product would function in accordance with all software prompts and documentation. The data sets, MIC execution procedure, and work-flow plan discussed in the following paragraphs were used in the evaluation process.

Preliminary evaluation

A preliminary product evaluation was accomplished using data sets provided by Intergraph Corporation. These data sets included piping, mechanical equipment, and structural steel components with both hard and soft areas for interference detection. This evaluation was primarily used to familiarize the reviewers with the MIC application and its operation. Results from this evaluation are not included in this report.

Final evaluation

Final evaluation was performed using data from a project completed by the U.S. Army Engineer District, Japan (JED), Pacific Ocean Division; included in the design were a swimming pool, gymnasium, spectator seating area, and other fitness facilities.

For the evaluation, Intergraph applications were used to produce architectural (P-Arch), mechanical (PE-Pipe and PE-HVAC), and structural (P-Arch) designs for the facility. Although the original designs received from JED were devoid of interferences, the files were modified at predetermined locations so that interferences would occur between the P-Arch, PE-Pipe, and PE-HVAC files. Application software and design

10

files were loaded and a project created in accordance with instructions provided in the MIC user's guide.[1]

Intlfc

For the IntIfc evaluation, the identical data from the MIC evaluation were used. IntIfc was initiated and detection of interfering elements occurred that was consistent with the previous MIC evaluation with the exceptions as described in Chapter 4. Because IntIfc does not perform interference checking between reference files, interferences between reference files were not identified.

---

[1] Intergraph Corporation. (1993). "Model interference checker user's guide," Huntsville, AL.

4 Evaluation Results

MIC

Data were evaluated using MIC version 04.03.01. An Intergraph representative was available throughout this evaluation. In the course of the evaluation, serious software deficiencies were discovered that prompted Intergraph, via the Intergraph representative, to request a new version of MIC without these deficiencies.

The data were again evaluated with the new version of MIC, version 04.03.02. The change from version 04.03.01 to version 04.03.02 corrected the software dependency problems among P-Arch, PE-HVAC, and PE-Pipe. These compatibility problems emphasized the need for care in ascertaining the compatibility of various software packages required for MIC operation.

Appendixes B, C, and D present typical interference reports generated by MIC as part of the evaluation. Appendix B gives an overall synopsis of all interferences detected. Interferences occurring within the envelope files bceqp01.env, bcpipe01.env, and sarea38p.env are listed, followed by interferences occurring between pairs of envelope files (bceqp01.env and sarea38p.env, etc.). Appendix C lists specific locations where interferences were detected. Interferences are organized by order of precedence beginning with hard/hard interferences. As with Appendix B, Appendix C lists interference locations internal to the envelope files first, followed by interferences between pairs of envelope files. Appendix D presents a set of graphic representations showing each of the interferences detected in order of precedence beginning with hard/hard for internal interferences within an envelope file, followed by interferences detected between pairs of envelope files.

Intlfc

IntIfc successfully detected interferences. However, several problems were experienced and are enumerated in Appendix F.

12

5 Conclusions and Recommendations

Conclusions

Software dependency problems

Evaluation of the data sets highlighted the impact of software dependency problems. Using MIC version 04.03.01, serious software incompatibilities were discovered that ultimately resulted in failure of MIC to perform for the product evaluation. At the urging of the Intergraph representative, a newer version of MIC, version 04.03.02, was obtained that ultimately became functional following correction of several software dependency problems.

Software installation

Software installation was undoubtedly exacerbated by the software dependency problems. However, the services of a System Manager or Database Manager greatly facilitated the software loading and installation process.

MIC performance

MIC was a very comprehensive application covering all element conflict types that had been installed in the data sets examined. Reporting was very detailed and informative, with the exception of the coordinate list for each interfering model, which proved to be of little value. Plots were, in general, easy to read, describing all interferences in detail.

Form screens

A number of problems involving the complexity of the form screens resulted in a significant amount of time being required to interpret the meaning and intent of the forms before information could be input to the system. Specific problems that were encountered using the form screens are described in Appendix G.

Recommendations

The MIC product that was developed and evaluated in connection with this CPAR project was still in a developmental stage and, as such, had not benefitted from beta testing and feedback from field use. As a result, many of the problems with software dependencies, form screen sequences and nomenclature, and the organization and clarity of the user's guide that were encountered would not normally be experienced. The form screen problems were not considered to be serious, but they were problems that users of the MIC product should be aware of and be prepared to deal with when installing and using MIC.

The results of this evaluation showed that use of the MIC product, when it has reached maturity, can be expected to be beneficial to the construction industry and to the tri-service community of CADD/GIS users. Initial installation and setup problems notwithstanding, the MIC product successfully performed the tasks of detecting and reporting interferences. MIC's greatest benefit will probably be seen in large processing plant design and not standard commercial/government building design. Because of its setup complexity and requirements for extremely accurate 3-D models, MIC will be less productive in standard building design. Some design disciplines, particularly mechanical and electrical, still design using two-dimensional drawings only. For MIC to function at its true potential, these disciplines will be forced to design completely in 3-D.

Commercialization/Technology Transfer

Intergraph Corporation

The CPAR partner has introduced the MIC product to the construction industry and is promoting and marketing the product, its post-sale support, and implementation guidance and support through their regular marketing channels. The MIC product, identified as Interference Checker (SE**213), is available to the tri-service community under Facilities CAD-2 Contract Number N66032-93-D-0021.

14

Tri-Service CADD/GIS Technology Center

The resources of the Tri-Service CADD/GIS Technology Center, WES, are being used to inform the CADD/GIS user community in the Army, Navy, Air Force, and Corps of Engineers of the availability of the MIC product, as follows:

a. The October 1993 issue of the *CADD/GIS Bulletin*[1] introduced MIC in an article entitled "Interdisciplinary Interference Checker Evaluated."

b. Planning is under way for workshops to train personnel on the procedures for installing and using the MIC software for interference checking. A course guide, developed by Intergraph,[2] is being used as guidance for the preparation and presentation of workshop training. The workshops, which will be held in the training facilities of the Information Technology Laboratory, Waterways Experiment Station, will consist of both lectures and hands-on experience in procedures for installing and using the MIC product and development of the files required for proper MIC operation.

---

[1] A. Williamson. (1993). "Interdisciplinary interference checker," *CADD/GIS Bulletin*, Vol 93-2, Tri-Service CADD/GIS Technology Center, U.S. Army Engineer Waterways Experiment Station, Vicksburg, MS.

[2] Intergraph Corporation. (1993). "Model interference checker user's guide," Huntsville, AL.

Appendix A
Design Disciplines in the Project Design Model

DESIGN DISCIPLINES AND RESPONSIBILITIES

DESIGN

Geotechnical	Environmental (HTRW)	Civil/Site	Architectural	Landscape Architectural	Interior Systems	Structural	Mechanical	Electrical

Subsurface Soil Exploration
Stability Analysis
Bearing Analysis
Dewatering Analysis
Seepage Analysis
		Potable Water
		Sewer
		Roads/Highways
		Bridges
		Security
		Drainage
				Vehicular Planning
				Irrigation
				Site Design
				Planting Design
						Buildings/Structures
						Steel/Concrete/Timber
						  Member Analysis and
						  Design
						Masonry Analysis and Design
								Power
								Communications
								Controls
								Instrumentation

	Sampling Chemical Characterization Remedial Design		Facility Programming Spatial Planning Site Design Schematic Design Handicapped Accessibility		Ergonomics Aesthetics Spatial Planning		HVAC Plumbing Hydraulics Machines Fuel Systems	

CONSTRUCTION

Shop Drawings	Submittals	Quality Assurance	Modifications	Claims Negotiations	Requests for Information	Acceptance	As-Built Drawings

Adherence to Design
  and Specifications
  and Standard
  Construction Practices
		Inspections
		Safety
		Testing
				Government Estimate
				Contractor's Claims
				Bargaining
				Settlements
						Final Inspection
						Operator Training	

	Catalog Cuts
	Worker Certifications
	Specifications
	  Adherence
			Government Estimates
			Contractor's Proposals
			Contract Impact Assessment
					Contractor Requests
					Designer Solutions
					Modification
					  Determination
					Clarifications
							Construction Mark-Ups
							Finished Drawings

Appendix B
Synopsis of Clashes

```
                    PDS Interference Synopsis


  bceqp01.env
  Number of clashes = 0


  bcpipe01.env
  Number of clashes = 7


  sarea38p.env
  Number of clashes = 0


  bceqp01.env
  sarea38p.env
  Number of clashes = 7


  bceqp01.env
  bcpipe01.env
  Number of clashes = 7


  bcpipe01.env
  sarea38p.env
  Number of clashes = 5
```

Appendix C
Locations of Clashes

```
                          PDS Interference Report

                   Date:  22-Jul-93      Time:  16:27:53

          Model 'A' Design File Name:  bcpipe01

          Entire Design Volume Included In Report

                        PDS Interference Clashes
                           Hard/Hard Clashes
```

No	Item Name	Table	Row	X Coord	Y Coord	Z Coord
1	GAT 101-6"-1C0031-P-6 "	3	33554553	E 1319' 1 13/32" PlaN	344' 10 1/16" PlanEl	16' 8 19/32" Plan
1	PIPE 101-6"-1C0031-P-6 "	5	33554495	E 1319' 1 13/32" PlaN	347' 1 1/16" PlantEl	14' 9 15/32" Plan

```
                        PDS Interference Clashes
                           Hard/Soft Clashes
```

No	Item Name	Table	Row	X Coord	Y Coord	Z Coord
2	E45LR 101-6"-1C0031-P-6 "	3	33554548	E 1319' 1 13/32" PlaN	356' 8 13/16" PlanEl	14' 0 15/32" Plan
2	PIPE 101-6"-1C0031-P-6 "	5	33554494	E 1319' 1 13/32" PlaN	356' 5 1/16" PlantEl	14' 0 15/32" Plan
3	PIPE 101-6"-1C0031-P-6 "	5	33554491	E 1319' 1 13/32" PlaN	356' 11 15/32" PlaEl	14' 3 1/8" Plant
3	E45LR 101-6"-1C0031-P-6 "	3	33554549	E 1319' 1 13/32" PlaN	361' 4 17/32" PlanEl	18' 8 3/16" Plant
4	PIPE 101-6"-1C0031-P-6 "	5	33554492	E 1319' 1 13/32" PlaN	361' 4 17/32" PlanEl	18' 11 15/16" Pla
4	E90LR 202-6"-1C0031-N-0 "	3	33554558	E 1319' 8 29/32" PlaN	361' 4 17/32" PlanEl	23' 11 15/16" Pla
5	PIPE 101-6"-1C0031-P-6 "	5	33554492	E 1319' 1 13/32" PlaN	361' 4 17/32" PlanEl	18' 11 15/16" Pla
5	PIPE 202-6"-1C0031-N-0 "	5	33554500	E 1319' 8 29/32" PlaN	361' 4 17/32" PlanEl	24' 8 15/16" Plan

```
                        PDS Interference Clashes
                           Soft/Soft Clashes
```

No	Item Name	Table	Row	X Coord	Y Coord	Z Coord
6	E45LR 101-6"-1C0031-P-6 "	3	33554548	E 1319' 1 13/32" PlaN	356' 8 13/16" PlanEl	14' 0 15/32" Plan
6	PIPE 101-6"-1C0031-P-6 "	5	33554491	E 1319' 1 13/32" PlaN	356' 11 15/32" PlaEl	14' 3 1/8" Plant

| 7 | E45LR
101-6"-1C0031-P-6 " | 3 | 33554549 | E 1319' 1 13/32" PlaN 361' 4 17/32" PlanEl 18' 8 3/16" Plant |
| 7 | PIPE
101-6"-1C0031-P-6 " | 5 | 33554492 | E 1319' 1 13/32" PlaN 361' 4 17/32" PlanEl 18' 11 15/16" Pla |

```
                         PDS Interference Report

                    Date:  22-Jul-93      Time:  16:28:32

         Model 'A' Design File Name:  bceqp01

         Entire Design Volume Included In Report



         Model 'B' Design File Name:  sarea38p

         Entire Design Volume Included In Report

                          PDS Interference Clashes
                             Hard/Hard Clashes

  No       Item Name          Table    Row   X Coord         Y Coord         Z Coord
  —       ————————          ————    ——    ——————        ——————         ——————

  15       TANK1               21      3    E 1317' 7 13/32" PlaN 355' 6 1/16" PlantEl 16' 2 15/32" Plan

  15       Volume : V5         34      5    E 1322' 11 13/32" PlN 351' 10 1/16" PlanEl 14' 2 15/32" Plan


  16       TANK1               21      3    E 1325' 1 13/32" PlaN 357' 6 1/16" PlantEl 10' 2 15/32" Plan

  16       Volume : V10        34     10    E 1320' 7 13/32" PlaN 349' 6 1/16" PlantEl 12' 2 15/32" Plan


  17       TANK1               21      3    E 1317' 7 13/32" PlaN 355' 6 1/16" PlantEl 16' 2 15/32" Plan

  17       Column : C16        34     16    E 1323' 5 31/32" PlaN 352' 11 1/8" PlantEl 14' 4 7/32" Plant


  18       TANK1               21      3    E 1317' 7 13/32" PlaN 355' 6 1/16" PlantEl 16' 2 15/32" Plan

  18       Brace : BR30        34     30    E 1323' 7 31/32" PlaN 352' 6 3/32" PlantEl 14' 4 7/32" Plant


  19       TANK1               21      3    E 1317' 7 13/32" PlaN 355' 6 1/16" PlantEl 16' 2 15/32" Plan

  19       Brace : BR34        34     34    E 1323' 7 31/32" PlaN 352' 6 3/32" PlantEl 14' 4 7/32" Plant


  20       TANK2               21      4    E 1315' 1 15/32" PlaN 366' 11 29/32" PlaEl 23' 4 15/32" Plan

  20       Beam : B28          34     28    E 1310' 11 15/32" PlN 352' 6 3/32" PlantEl 25' 4 7/32" Plant

                          PDS Interference Clashes
                             Hard/Soft Clashes

  No       Item Name          Table    Row   X Coord         Y Coord         Z Coord
  —       ————————          ————    ——    ——————        ——————         ——————

  21       TANK3               21      5    E 1319' 1 13/32" PlaN 349' 6 1/16" PlantEl 10' 2 15/32" Plan

  21       Volume : V10        34     10    E 1320' 7 13/32" PlaN 349' 6 1/16" PlantEl 12' 2 15/32" Plan
```

```
                          PDS Interference Report

                  Date:  22-Jul-93        Time:  16:29:14

           Model 'A' Design File Name:  bceqp01

           Entire Design Volume Included In Report


           Model 'B' Design File Name:  bcpipe01

           Entire Design Volume Included In Report

                          PDS Interference Clashes
                             Hard/Hard Clashes

    No      Item Name          Table     Row     X Coord        Y Coord          Z Coord
    ─                          ─────      ───
    8       TANK1                21         3    E 1317' 7 13/32" PlaN 355' 6 1/16" PlantEl 16' 2 15/32" Plan

    8       PIPE                  5   33554491   E 1319' 1 13/32" PlaN 356' 11 15/32" PlaEl 14' 3 1/8" Plant
            101-6"-1C0031-P-6 "

    9       TANK3                21         5    E 1319' 1 13/32" PlaN 349' 6 1/16" PlantEl 10' 2 15/32" Plan

    9       PIPE                  5   33554494   E 1319' 1 13/32" PlaN 356' 5 1/16" PlantEl 14' 0 15/32" Plan
            101-6"-1C0031-P-6 "

    10      TANK3                21         5    E 1319' 1 13/32" PlaN 349' 6 1/16" PlantEl 10' 2 15/32" Plan

    10      PIPE                  5   33554497   E 1319' 1 13/32" PlaN 345' 7 1/16" PlantEl 10' 2 15/32" Plan
            101-6"-1C0031-P-6 "

                          PDS Interference Clashes
                             Hard/Soft Clashes

    No      Item Name          Table     Row     X Coord        Y Coord          Z Coord
    ─                          ─────      ───
    11      TANK1                21         3    E 1319' 1 13/32" PlaN 357' 6 1/16" PlantEl 10' 2 15/32" Plan

    11      E45LR                 3   33554548   E 1319' 1 13/32" PlaN 356' 8 13/16" PlanEl 14' 0 15/32" Plan
            101-6"-1C0031-P-6 "

    12      TANK1                21         3    E 1319' 1 13/32" PlaN 357' 6 1/16" PlantEl 10' 2 15/32" Plan

    12      PIPE                  5   33554494   E 1319' 1 13/32" PlaN 356' 5 1/16" PlantEl 14' 0 15/32" Plan
            101-6"-1C0031-P-6 "

    13      TANK3                21         5    E 1319' 1 13/32" PlaN 349' 6 1/16" PlantEl 10' 2 15/32" Plan

    13      E90LR                 3   33554554   E 1319' 1 13/32" PlaN 347' 1 1/16" PlantEl 14' 0 15/32" Plan
            101-6"-1C0031-P-6 "

                          PDS Interference Clashes
                             Soft/Soft Clashes

    No      Item Name          Table     Row     X Coord        Y Coord          Z Coord
```

| 14 | TANK3 | 21 | 5 | E 1319' 1 13/32" PlaN 349' 6 1/16" PlantEl 10' 2 15/32" Plan |
| 14 | PIPE 101-6"-1C0031-P-6 " | 5 | 33554495 | E 1319' 1 13/32" PlaN 347' 1 1/16" PlantEl 14' 9 15/32" Plan |

```
                                PDS Interference Report

                        Date:  22-Jul-93        Time:  16:29:52

            Model 'A' Design File Name:  bcpipe01

            Entire Design Volume Included In Report



                Model 'B' Design File Name:  sarea38p

            Entire Design Volume Included In Report


                            PDS Interference Clashes
                                Hard/Hard Clashes

  No      Item Name              Table      Row    X Coord         Y Coord          Z Coord
  —       —————                  ————       ———    —————           —————            —————

  22      PIPE                      5     33554492  E 1319' 1 13/32" PlaN 361' 4 17/32" PlanEl 18' 11 15/16" Pla
          101-6"-1C0031-P-6 "

  22      Brace : BR37             34         37   E 1310' 7 31/32" PlaN 352' 6 3/32" PlantEl 25' 4 7/32" Plant

  23      PIPE                      5     33554498  E 1323' 4 15/32" PlaN 341' 4 17/32" PlanEl 23' 11 15/16" Pla
          202-6"-1C0031-N-0 "

  23      Column : C16             34         16   E 1323' 5 31/32" PlaN 352' 11 1/8" PlantEl 14' 4 7/32" Plant

  24      PIPE                      5     33554498  E 1323' 4 15/32" PlaN 341' 4 17/32" PlanEl 23' 11 15/16" Pla
          202-6"-1C0031-N-0 "

  24      Beam : B25               34         25   E 1310' 7 31/32" PlaN 352' 2 9/16" PlantEl 25' 4 7/32" Plant

  25      GAT                       3     33554559  E 1323' 4 15/32" PlaN 357' 4 17/32" PlantEl 23' 11 15/16" Pla
          202-6"-1C0031-N-0 "

  25      Beam : B27               34         27   E 1323' 4 15/32" PlaN 380' 0 3/32" PlantEl 25' 4 7/32" Plant

  26      FWN                       3     33554561  E 1323' 4 15/32" PlaN 356' 9 13/32" PlanEl 23' 11 15/16" Pla
          202-6"-1C0031-N-0 "

  26      Beam : B27               34         27   E 1323' 4 15/32" PlaN 380' 0 3/32" PlantEl 25' 4 7/32" Plant
```

Appendix D
# Graphic Display of Clashes

ACTION :

OWNER :

RETURN FOR APPROVAL :

TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 1	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPIPE01
ITEM   A : GAT
    101-6"-1C0031-P-6 "

MODEL B : BCPIPE01
ITEM   B : PIPE
    101-6"-1C0031-P-6 "

E 1318'1 29/32" PLANT
N 343'10 9/16" PLANT
EL14'9 15/32" PLANT

E 1320'0 29/32" PLANT
N 347'10 3/8" PLANT
EL17'5 15/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:27:47 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 2	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCPIPE01	MODEL B : BCPIPE01
ITEM A : E45LR	ITEM B : PIPE
101-6"-1C0031-P-6 "	101-6"-1C0031-P-6 "
E 1318' 4 3/32" PLANT	E 1319' 10 23/32" PLANT
N 347' 10 1/16" PLANT	N 357' 6 1/32" PLANT
El 13' 3 5/32" PLANT	El 14' 10 23/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:27:54 1993

| ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

NORTH
EAST

ISO

UP
NORTH EAST

LOOKING NORTH

UP
EAST

LOOKING EAST

UP
SOUTH

CLASH : 3	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCPPE01
ITEM A : PIPE
   101-6"-1C0031-P-6 "
	MODEL B : BCPPE01
	ITEM B : E45LR
	   101-6"-1C0031-P-6 "

E 1318'4 3/32" PLANT N 356'4 7/8" PLANT El 13'8 17/32" PLANT	E 1319'10 23/32" PLANT N 362'1 27/32" PLANT El 19'1 3/4" PLANT

PROJECT : PDS1	AREA : ·	THU JUL22 16:27:59 1993

D4

Appendix D Graphic Display of Clashes

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN	ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH	LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 4	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCPIPE01 ITEM A : PIPE 101-6"-1C0031-P-6 "	MODEL B : BCPIPE01 ITEM B : E90LR 202-6"-1C0031-N-0 "
E 1318' 4 3/32" PLANT N 360' 7 7/32" PLANT El 18' 11 15/16" PLANT	E 1320' 5 29/32" PLANT N 362' 1 27/32" PLANT El 28' 11 15/16" PLANT

PROJECT : PDS1	AREA : ·	THU JUL 22 16:28:05 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH   EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 5	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCPIPE01	MODEL B : BCPIPE01
ITEM A : PIPE	ITEM B : PIPE
101-6'-1C0031-P-6 '	202-6'-1C0031-N-0 '

E 1318' 4 3/32" PLANT	E 1320' 0 7/32" PLANT
N 360' 7 7/32" PLANT	N 362' 1 27/32" PLANT
EL 18' 11 15/16" PLANT	EL 28' 11 15/16" PLANT

| PROJECT : PDS1	AREA :	THU JUL 22 16:28:10 1993

D6

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH

LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 6	STATUS : UNAPPROVED	CLASH TYPE : SOFT VERSUS SOFT

MODEL A : BCPIPE01
ITEM A : E45LR
  101-6"-1C0031-P-6 "
	MODEL B : BCPIPE01
	ITEM B : PIPE
	  101-6"-1C0031-P-6 "

E 1318' 4 3/32" PLANT N 356' 3 1/4" PLANT EL 13' 3 5/32" PLANT	E 1319' 10 23/32" PLANT N 361' 8 15/32" PLANT EL 19' 0 1/8" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:28:15 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN	ISO
NORTH EAST	UP NORTH EAST

LOOKING NORTH	LOOKING EAST
UP EAST	UP SOUTH

CLASH : 7	STATUS : UNAPPROVED	CLASH TYPE : SOFT VERSUS SOFT

MODEL A : BCPPE01
ITEM A : E45LR
  101-6'-1C0031-P-6 '
	MODEL B : BCPPE01
	ITEM B : PIPE
	  101-6'-1C0031-P-6 '

E 1318'4 3/32' PLANT N 360'6 9/32' PLANT EL17'10 31/32' PLANT	E 1319'10 23/32' PLANT N 362'1 27/32' PLANT EL28'11 15/16' PLANT

| PROJECT : PDS1	AREA :	THU JUL22 16:28:21 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

NORTH
EAST

ISO

UP
NORTH EAST

LOOKING NORTH

UP
EAST

LOOKING EAST

UP
SOUTH

CLASH : 8	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01 ITEM A : TANK1	MODEL B : BCPPE01 ITEM B : PPE 101-6"-1C0031-P-6 "
E 1315'10 13/32" PLANT N 352'0 1/16" PLANT EL 10'2 15/32" PLANT	E 1329'4 13/32" PLANT N 361'8 15/32" PLANT EL 19'8 15/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:29:11 1993

| ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

NORTH
EAST

ISO

UP
NORTH EAST

LOOKING NORTH

UP
EAST

LOOKING EAST

UP
SOUTH

CLASH : 9	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01 ITEM A : TANK3	MODEL B : BCPPE01 ITEM B : PIPE 101-6"-IC0031-P-6 "
E 1317'1 13/32" PLANT N 347'6 1/16" PLANT EL10'2 15/32" PLANT	E 1321'1 13/32" PLANT N 356'5 1/16" PLANT EL15'2 15/32" PLANT

PROJECT : PDS1   AREA : ·   THU JUL22 16:29:16 1993

ACTION :		OWNER :	
RETURN FOR APPROVAL :		TRANSFER TO :	

PLAN

ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH

LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 10	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01	MODEL B : BCPIPE01
ITEM A : TANK3	ITEM B : PIPE
	101-6"-1C0031-P-6 "

E 1317'1 13/32' PLANT	E 1321'1 13/32' PLANT
N 345'7 1/16' PLANT	N 351'6 1/16' PLANT
El 9'5 5/32' PLANT	El 15'2 15/32' PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:29:21 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH

LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 11	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCEQP01
ITEM A : TANK1

MODEL B : BCPIPE01
ITEM B : E45LR
   101-6"-1C0031-P-6 '

E 1315'10 13/32" PLANT
N 352'0 1/16" PLANT
EL10'2 15/32" PLANT

E 1329'4 13/32" PLANT
N 359'0 1/16" PLANT
EL19'8 15/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:29:26 1993

D12

ACTION :   OWNER :

RETURN FOR APPROVAL :   TRANSFER TO :

PLAN   ISO

NORTH   UP
  └EAST   NORTH EAST

LOOKING NORTH   LOOKING EAST

UP   UP
  └EAST   └SOUTH

CLASH : 12	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCEQP01 ITEM A : TANK1	MODEL B : BCPIPE01 ITEM B : PIPE 101-6"-1C0031-P-6 "
E 1315' 10 13/32" PLANT N 347' 10 1/16" PLANT EL 10' 2 15/32" PLANT	E 1329' 4 13/32" PLANT N 359' 0 1/16" PLANT EL 19' 8 15/32" PLANT

PROJECT : PDS1   AREA : ·   THU JUL 22 16:29:32 1993

| ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

NORTH

EAST

ISO

UP

NORTH EAST

LOOKING NORTH

UP

EAST

LOOKING EAST

UP

SOUTH

CLASH : I3	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCEOP01 ITEM A : TANK3	MODEL B : BCPIPE01 ITEM B : E90LR 101-6"-IC0031-P-6 "
E 1317'1 13/32" PLANT N 346'3 3/4" PLANT EL10'2 15/32" PLANT	E 1321'1 13/32" PLANT N 351'6 1/16" PLANT EL15'2 15/32" PLANT

PROJECT : PDS1	AREA :	THU JUL22 16:29:37 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH   EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 14	STATUS : UNAPPROVED	CLASH TYPE : SOFT VERSUS SOFT

MODEL A : BCEQP01 ITEM A : TANK3	MODEL B : BCPIPE01 ITEM B : PIPE 101-6"-1C0031-P-6 '
E 1317'1 13/32" PLANT N 346'3 3/4" PLANT EL 10'2 15/32" PLANT	E 1321'1 13/32" PLANT N 351'6 1/16" PLANT EL 17'5 15/32" PLANT

PROJECT : PDS1   AREA :   THU JUL 22 16:29:43 1993

ACTION :

OWNER :

RETURN FOR APPROVAL :

TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 15	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01	MODEL B : SAREA38P
ITEM A : TANK1	ITEM B : VOLUME : V5

E 1315'10 13/32" PLANT	E 1329'4 13/32" PLANT
N 351'10 1/16" PLANT	N 359'0 1/16" PLANT
El 10'2 15/32" PLANT	El 19'8 15/32" PLANT

PROJECT : PDS1   AREA :   THU JUL 22 16:28:28 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

NORTH
EAST

ISO

UP
NORTH EAST

LOOKING NORTH

UP
EAST

LOOKING EAST

UP
SOUTH

CLASH : 16	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD
MODEL A : BCEQP01 ITEM A : TANK1		MODEL B : SAREA38P ITEM B : VOLUME : V10
E 1315'10 13/32" PLANT N 349'6 1/16" PLANT EL 10'2 15/32" PLANT		E 1329'4 13/32" PLANT N 359'0 1/16" PLANT EL 19'8 15/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:28:34 1993

Appendix D Graphic Display of Clashes

ACTION :

OWNER :

RETURN FOR APPROVAL :

TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 17	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01
ITEM   A : TANK1

MODEL B : SAREA38P
ITEM   B : COLUMN C16

E 1315'10 13/32" PLANT
N 352'0 1/16" PLANT
El 10'2 15/32" PLANT

E 1329'4 13/32" PLANT
N 359'0 1/16" PLANT
El 25'4 7/32" PLANT

PROJECT : PDS1   AREA :   THU JUL 22 16:28:40 1993

D18

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH

LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 18	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEOP01	MODEL B : SAREA38P
ITEM A : TANK1	ITEM B : BRACE : BR30

E 1315' 10 13/32" PLANT	E 1329' 4 13/32" PLANT
N 352' 0 1/16" PLANT	N 366' 3 3/32" PLANT
EL 10' 2 15/32" PLANT	EL 25' 6 15/16" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:28:46 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 19	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01	MODEL B : SAREA38P
ITEM A : TANK1	ITEM B : BRACE :BR34

E 1310' 7 31/32" PLANT	E 1329' 4 13/32" PLANT
N 352' 0 1/16" PLANT	N 359' 0 1/16" PLANT
El 10' 2 15/32" PLANT	El 25' 8 13/16" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:28:52 1993

D20

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH   EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 20	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCEQP01
ITEM A : TANK2

MODEL B : SAREA38P
ITEM B : BEAM :B28

E 1310'1 15/32" PLANT
N 352'6 3/32" PLANT
EL10'2 15/32" PLANT

E 1320'1 15/32" PLANT
N 380'0 3/32" PLANT
EL27'2 15/32" PLANT

PROJECT :   PDSI   AREA :   THU JUL22 16:28:59 1993

ACTION :

OWNER :

RETURN FOR APPROVAL :

TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 21	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS SOFT

MODEL A : BCEQP01
ITEM   A : TANK3

MODEL B : SAREA38P
ITEM   B : VOLUME : V10

E 1317'1 13/32" PLANT
N 347'6 1/16" PLANT
EL10'2 15/32" PLANT

E 1326'7 13/32" PLANT
N 355'6 1/16" PLANT
EL15'2 15/32" PLANT

PROJECT : PDS1   AREA : ·   THU JUL22 16:29:04 1993

D22

ACTION :

OWNER :

RETURN FOR APPROVAL :

TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 22	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPPE01
ITEM A : PIPE
   101-6"-1C0031-P-6 "

MODEL B : SAREA38P
ITEM B : BRACE :BR37

E 1310' 3 5/8" PLANT
N 352' 6 3/32" PLANT
EL 18' 11 15/16" PLANT

E 1323' 7 31/32" PLANT
N 366' 7 3/16" PLANT
EL 28' 11 15/16" PLANT

PROJECT : PDSI	AREA :	THU JUL 22 16:29:48 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH

EAST

UP

NORTH   EAST

LOOKING NORTH

LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 23	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPIPE01 ITEM A : PIPE 202-6'-IC0031-N-0 '	MODEL B : SAREA38P ITEM B : COLUMN : C16
E 1323'15/32' PLANT N 341'4 17/32' PLANT EL14'4 7/32' PLANT	E 1323'9 31/32' PLANT N 356'7 21/32' PLANT EL25'4 7/32' PLANT

PROJECT : PDS1 AREA : ·	THU JUL22 16:29:54 1993

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN

ISO

NORTH
EAST

UP
NORTH EAST

LOOKING NORTH

LOOKING EAST

UP
EAST

UP
SOUTH

CLASH : 24	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPIPE01 ITEM A : PIPE 202-6"-1C0031-N-0 "	MODEL B : SAREA38P ITEM B : BEAM : B25
E 1310' 7 31/32" PLANT N 341' 4 17/32" PLANT EL23' 4 21/32" PLANT	E 1323' 7 31/32" PLANT N 356' 7 21/32" PLANT EL25' 4 7/32" PLANT

PROJECT : PDSI	AREA :	THU JUL22 16:29:59 1993

PLAN

NORTH
EAST

ISO

UP
NORTH EAST

LOOKING NORTH

UP
EAST

LOOKING EAST

UP
SOUTH

CLASH : 25	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPIPE01 ITEM A : GAT 202-6"-1C0031-N-0 "	MODEL B : SAREA38P ITEM B : BEAM : B27
E 1322' 10 31/32" PLANT N 352' 6 3/32" PLANT EL23' 4 3/16" PLANT	E 1326' 3 27/32" PLANT N 380' 0 3/32" PLANT EL25' 4 7/32" PLANT

PROJECT : PDS1	AREA :	THU JUL 22 16:30:06 1993

Appendix D Graphic Display of Clashes

ACTION :	OWNER :
RETURN FOR APPROVAL :	TRANSFER TO :

PLAN	ISO

NORTH

EAST

UP

NORTH EAST

LOOKING NORTH	LOOKING EAST

UP

EAST

UP

SOUTH

CLASH : 26	STATUS : UNAPPROVED	CLASH TYPE : HARD VERSUS HARD

MODEL A : BCPIPE01	MODEL B : SAREA38P
ITEM A : FWN	ITEM B : BEAM : B27
202-6"-IC0031-N-0 "	

E 1322'10 31/32" PLANT	E 1323'11 15/32" PLANT
N 352'6 3/32" PLANT	N 380'0 3/32" PLANT
EL23'4 21/32" PLANT	EL25'4 7/32" PLANT

PROJECT : PDS1	AREA : ·	THU JUL22 16:30:11 1993

Appendix E
General Description of
Application Software

Project Architect

Project Architect, also known as P-Arch, is a workstation-based architectural drafting and design product capable of creating 3-D models, 2-D floor plans, building sections, elevation drawings, reflected ceiling plans, and roof plans. P-Arch provides the capability for managing database (nongraphic) information such as room numbers, material quantities, and other project data using relational databases.

Nongraphic Information

Databases are used by P-Arch to associate nongraphic information with graphic elements in design files. P-Arch provides the interface for the maintenance and operation of project databases. A structured query language (SQL) interface is indigenous to P-Arch and most common relational databases used by Intergraph.

The SQL interface differences in relational database management systems (RDBMS's) provided by vendors are identified by a relational interface system (RIS) so that RIS can provide a generic networked access to all architectural databases. As a result, all architectural databases generated with RDBMS's and supported by RIS, including Informix Standard Engine and On-line, Oracle, and Ingres, are accessible.

An RIS schema, created by the user, defines the information in an RDBMS that is related to a particular project database. The RIS schema is utilized by P-Arch to identify a unique database/user combination in the commercial database system. As a result of the various interfaces provided with P-Arch, a user is not required to know the syntax of the RIS create schema statements to efficiently maintain databases through RIS.

Project Engineer-HVAC (PE-HVAC)

PE-HVAC provides the design engineer with the capability to lay out, size, and model HVAC ducts and fittings, select and place HVAC devices, label drawings, create reports from a design, modify existing HVAC drawings, add to existing drawings, and check for spatial interferences. When using this application, HVAC system designs are created by placing fittings and devices and laying out duct routes. Ducts may be defined by lines or arcs with a cross section at one end to provide a visualization of duct sizes, shapes, and justifications. An interactive duct-sizing calculator provides the capability to presize or resize ducts. The results are applied not only to the duct design but also to fittings that are incorporated into the design.

PE-HVAC product information is provided in the "Project Engineer HVAC (PE-HVAC) Reference Guide (DEA100350)."[1]

Project Engineer-Pipe (PE-Pipe)

The functionality of PE-Pipe is much the same as that of PE-HVAC, except that PE-Pipe is used for pipe layout and designs.

---

[1] Intergraph Corporation. (1993). "Project Engineer HVAC (PE-HVAC) Reference Guide — Volumes 1 and 2," Huntsville, AL.

Appendix F
Specific Problems Encountered
in IntIfc

Problems encountered with IntIfc included:

a. When prompted with the Review/Display Interferences dialogue box, the workstation locked up any time a data point was entered. This problem was resolved by eliminating the Ustn-32 process at

/usr/ip32/mstation/umenu/bin/umenu

Once this was accomplished, use of IntIfc would continue without interruption.

b. In extremely complicated and congested design files, interferences were especially difficult to distinguish on the monitor screen. This was especially true when linework was defined as color white against white highlighted linework identifying interference locations.

c. IntIfc failed to detect interfering solid surfaces generated through use of the Derived Surfaces dialogue box, even though the interferences were clearly perceptible on the monitor screen.

d. The textual report produced by IntIfc was of little value other than identification of file names and directory paths of interfering elements.

Appendix G
Specific Problems Encountered in MIC

Problems

Problems encountered with MIC form screens included:

a. In a typical Intergraph project work flow, the Project Data Management form would normally be expected to follow the Interference Management form. However, these forms were reversed in their order in the MIC setup procedure.

b. The CREATE PROJECT form screen prompts for a directory. However, the specific directory requested is not clearly apparent. After several trial-and-error entries, the directory that should be entered at this point was the designation of the physical path to the project directory.

c. In the MicroStation environment, some of the standard MicroStation menus functioned only intermittently. In addition, the Top Bar Menu appeared distorted. The Top Bar distortion problem was caused by an improper seed file configuration from the seed file configuration information found on the back screen of a single monitor system.

d. The double click option for entry selection did not function on some form command screens.

User's Guide

The User's Guide, dated May 1993,[1] was the only guidance provided for using the MIC product. Comments on this document are enumerated below to assist any who may be using the MIC product before the User's Guide has been updated.

a. In the Preface, page ix of the User's Guide, under the heading "Document Purpose," the statement is made that the

"document is designed as a reference; it is organized around the structure of the product rather than presenting a typical work flow. Use this guide when you need to look up a specific Interference Checker/Manager function."

In view of this, care was required to NOT assume that the presentation of information was work-flow oriented.

b. In the Preface, page ix, under the heading "Document Prerequisites/ Audience," the statement is made that

"This document is intended for Project Managers who have a working knowledge of relational databases ..."

However, no instructional information on interface requirements for importing information from other application products or operating procedures was provided as expected.

c. In the Preface, page ix, under the heading "Related Documents/ Products," the reference to Interference Manager was not clear as to whether the reference was being made to the MIC product or to the Interference Manager form screen.

d. On page 1-2, the statement was made that "The Project Administrator controls the creation and modification of PDS 3D projects." However, the nomenclature, "PDS 3D projects," was never defined.

e. On pages 3-8 and 3-9, all references to coordinate system inputs are to the Plant Coordinate System. A pictorial example of a Plant Coordinate System monument is provided, but the applicability of this coordinate system to other applications, such as Project Architect, was never made clear. Intergraph later clarified this feature as not supported by MIC even though it is on the form.

---

[1] Intergraph Corporation. (1993). "Model interference checker user's guide," Huntsville, AL.

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

1. AGENCY USE ONLY *(Leave blank)*	2. REPORT DATE December 1994	3. REPORT TYPE AND DATES COVERED Final report

4. TITLE AND SUBTITLE
Interference Checking of Construction Design

5. FUNDING NUMBERS

6. AUTHOR(S)
Arthur Bennett, Ken Cook, Gregory A. Covington,
Laurel T. Gorman, Albert N. Williamson

7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)
U.S. Army Engineer District, Walla Walla, Bldg. 602, City County Airport,
Walla Walla, WA 99362-9265;
U.S. Army Engineer Waterways Experiment Station, 3909 Halls Ferry Road,
Vicksburg, MS 39180-6199

8. PERFORMING ORGANIZATION REPORT NUMBER
Technical Report CPAR-ITL-94-1

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)

10. SPONSORING/MONITORING AGENCY REPORT NUMBER

11. SUPPLEMENTARY NOTES
Available from National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161.

12a. DISTRIBUTION/AVAILABILITY STATEMENT
Approved for public release; distribution is unlimited.

12b. DISTRIBUTION CODE

13. ABSTRACT *(Maximum 200 words)*

A vital function of the Corps' mission is the design, construction, and maintenance of projects. These projects require complex drawings generated from computer-aided design and drafting (CADD) technology to support engineering construction and design tasks. To provide the basic tools necessary to analyze a design project and reduce construction problems associated with multidisciplinary drawings, a Construction Productivity Advancement Research (CPAR) project was initiated to specifically address spatial conflicts that occur with facility design drawings.

CPAR projects are based on ideas brought to the Corps by a prospective construction industry partner (or partners). All collaborative research and development projects under this program are aimed at improving domestic construction productivity and are required to be within the mission areas of the Corps. Participation in the program is open to any U.S. private firm, including corporations, partnerships, limited partnerships and industrial development organizations, public and private foundations, academic institutions, nonprofit organizations, units of state and local governments, and others who have an interest in and the capability to address CPAR objectives.

Under this CPAR project, software was developed to automate interference checking of CADD design drawings, including multidisciplinary engineering designs. The project stemmed from Intergraph Corporation proposal

(Continued)

14. SUBJECT TERMS
CADD conflicts   Interdisciplinary CADD conflicts
CADD software package   Intra-disciplinary
CPAR   Model interference checker

15. NUMBER OF PAGES
63

16. PRICE CODE

17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT	20. LIMITATION OF ABSTRACT

13. (Concluded).

No. 6-8903-21023, dated 23 May 1990, entitled "Cooperative Research and Development Agreement for Interdisciplinary Interference Checking Software." This resulted in CPAR No. 901-930.

This report describes the design functionality of the software products, the approach taken to evaluate them, the results obtained, conclusions reached on the basis of the evaluation, and recommendations. The report also describes the usefulness and limitations of the software products. These factors are addressed with recommended actions to facilitate use of the product by the U.S. construction industry.